



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Certificate No.: CE160314005227

**Product** MOULDED CASE CIRCUIT BREAKER

**Applicant** Changan Group Co.,Ltd.  
No.288 Wei 17th Road, Yueqing Economic Development Zone,  
Yueqing, Wenzhou, Zhejiang Province, P.R.China

**Type/model** CAMH-125 ,CAMH-125G

**Technical data** Ui: 400V; Ue:AC230V(1P),AC400V(2P,3P,4P); In: 63A,  
80A,100A,125A; Type of over-current release: Thermo-  
magnetic; Ics=Icu:4.5kA(CAMH-125), Ics=Icu:6kA(CAMH-  
125G); Selectivity category:A;1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No. (2016) FQIIDQCE-0097, the submitted sample of the above item complies with:

**EN 60947-2:2006+A1:2009+A2:2013**

and fulfill testing requirement of the European Directive:

**2014/35/EU**

Date of issue: Dec.08,2016

Date of expiration: Dec.08,2019

President



CHINA QUALITY CERTIFICATION CENTRE  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0004993