



Ref. Certif. No.

HU-003416

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCB

Name and address of the applicant

Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone, Yueqing, Wenzhou,
Zhejiang, P.R. China

Name and address of the manufacturer

Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone, Yueqing, Wenzhou,
Zhejiang, P.R. China

Name and address of the factory

Changan Group Co., Ltd.
NO.288 Wei17th Road,
Yueqing Economic Development Zone, Yueqing, Wenzhou,
Zhejiang, P.R. China

Ratings and principal characteristics

Ue=230/400V AC(1P); 400V AC (2P, 3P, 4P) 50/60Hz
In=6/10/16/20/25/32/40/50/63A (C/D-type)
Ics=Icn=4,5 kA for CABA-63 (a=2,6,X)
Ics=Icn=6,0 kA for CABA-63H (a=2,6,X)

Trademark (if any)

Chanan

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CABA-63 ; CABA-63H ;
(a=2,6,X)

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN216WSO 001

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN216WSO 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2021-04-26

Signature:

Wencai Zhang